



**SWAMI RAMANAND TEERTH MARATHWADA UNIVERSITY,
VISHNUPURI, NANDED (MAHARASHTRA)**

**ESTATE DEPARTMENT, S. R. T. M. UNIVERSITY, VISHNUPURI,
NANDED**

E-TENDER DOCUMENT

REF.NO. ESTATE/AIR CONDITIONERS/V.C. OFFICE/ET-16-2025

**E-TENDER FOR SUPPLY, INSTALLATION, TESTING &
COMMISSIONING OF DUCTABLE AIR CONDITIONERS
S.R.T.M.UNIVERSITY, NANDED (MAHARASHTRA)**

**REGISTRAR,
S.R.T.M.UNIVERSITY, NANDED**

**FOR MORE DETAILS VISIT THE PORTAL OF
<https://mahatenders.gov.in> or www.srtmun.ac.in**



INDEX

**E-TENDER FOR SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF DUCTABLE AIR CONDITIONERS
S.R.T.M.UNIVERSITY, NANDED (MAHARASHTRA)**

Sr.No.	Details of Contents	Page Nos.	
01	E-Tender Notice	03	03
02	Brief e-Tender Notice	04	04
03	Instructions for filling of Tender	05	06
04	General Terms & Conditions	07	08
05	Bidder's Declaration	09	09
06	Detail Specification	10	10
07	Tender Schedule	11	11
08	Appendix-II	12	12
09	BOQ	13	15



Swami Ramanand Teerth Marathwada University, Nanded

E-Tender No.: Estate/Air Conditioners/ET-16-2025

E-TENDER NOTICE

The Registrar, S.R.T.M. University, Nanded invites Tender for "Supply, Installation, Testing & Commissioning of Ductable Air Conditioners" from Manufacturer / Distributors / Authorized Dealers to participate in the competitive bidding process. For the detailed Tender document, interested bidders should visit <https://mahatenders.gov.in> / www.srtmun.ac.in

The filled tender booklet will be accepted on or before ~~19-09-2025~~ ^{19.09.2025} up to 3.00 p.m. The said e-Tender will be online open as per schedule if possible. Extension of Tender, Corrigendum or change in schedule will not be published in News paper; it will be published only at www.srtmun.ac.in / mahatenders.gov.in website only

Ref.: Estate/Ductable Air Conditioners/V.C. Office/ET-16-2025/ 166

Date 28/07/2025


Registrar

Copy to:

- 1) The System Expert, Computer Center, This University – With a request to upload the said Tender Booklet on our University web site.
- 2) Notice Board, Administrative Building, S.R.T.M. University, Nanded.
- 3) Notice Board, Estate Department, S.R.T.M. University, Nanded.


Registrar

स्वामी रामानंद तीर्थ
मराठवाडा विद्यापीठ, नांदेड



Swami Ramanand Teerth Marathwada University, Nanded
E-Tender No.: Estate/Ductable Air Conditioners/V.C. Office/ET-16-2025

BRIEF E-TENDER NOTICE


The Registrar, S.R.T.M.University, Nanded invites e-Tender for Supply of "Ductable Air Conditioners" from Manufacturer / Distributors / Authorized Dealers may submit the tender as per specifications, which are given in BOQ. The e-Tender Booklets are available on <https://mahatenders.gov.in> & our University website (www.srtmun.ac.in) from ~~12.07.2025~~ **19.07.2025** to **19.07.2025** up to 03.00 pm online payment of Rs.3600/- (Rupees Three thousand Six hundred only) (Non-refundable) as the cost of tender form. The last date for online submission of e-Tender on or before **19.07.2025 up to 03.00 p.m.** The said e-Tender will be online open as per schedule if possible.

The Registrar, S.R.T.M.University, Nanded reserves the right to accept any tenders or reject the lowest or any other or all tenders without assigning any reasons what so ever. Extension of tender, Corrigendum or change in schedule will not be published in News paper; it will be published only at www.srtmun.ac.in / <https://mahatenders.gov.in> website only.

Ref.: Estate/Ductable Air Conditioners/V.C. Office/ET-16-2025/ **L60**

Date **19/07/2025**

Registrar
स्वामी रामानंद तीर्थ
मराठवाडा विद्यापीठ



Instructions for filling of E-Tender

The Registrar, Swami Ramanand Teerth Marathwada University, Nanded invites E-Tender for Supply of **"Ductable Air Conditioner"** from **Manufacturer / Distributors / Authorized Dealers**. The details in this regard are given below.

1. Procedure to submit the tender:

The vendors should provide two sealed envelopes as given below

Envelop No.1 (Technical Bid):

- a) Cost of tender for **Rs.3,600/- (Non-refundable)** to be submitted online.
- b) Earnest Money Deposit of **Rs.18,000/ (Refundable)** to be submitted online.
- c) Registration certification under shop Act (नमुना 'ड') or company Act. or SSI or MSSI
- d) GST registration certificate
- e) Xerox copy of PAN Card
- f) Latest Income Tax Annual return.
- g) OEM (Original Equipment Manufacturer) Authorization.
- h) Bidder's Declaration for Acceptance of Terms & Condition of the tender (P.No.9 in Tender Booklet)
- i) Bidder should upload scan document of Appendix-II (Page No.12 to 12) for Company/Brand of said Ductable Air Conditioner to be Supply.

Envelop No. 2 (Financial Bid):-

The tendering authority will first open the Technical Bid documents of all Contractors and after scrutinizing these documents will shortlist the Bidders who are eligible for Financial Bidding process. Otherwise the tender may be disqualified. Financial bid should be submitted online by Vendor in Appendix- A & B in the form of **BOQ** excel sheet given over **www.mahatender.gov.in**. The supplier shall fill up the column of rate per unit offered by him.

Terms & conditions:


1. Bidder should have valid Digital Signature Certificate (DSC) obtained from any Certifying Authorities.
2. The specifications/details of the **"Ductable Air Conditioner"** provided in the tender booklet.
3. The Financial offers shall be submitted online as per the schedule.
4. University has the right to split the purchase order to more than one vendor/firms quoting lowest tender amount. Although before this, supplier will be invited for negotiations in University, if needed/required.
5. The Bidders are strictly advised to follow the dates and times allocated to each stage. As indicated in the time schedule. All the online activities are time tracked and the Electronic Tendering System enforces time-locks that ensure that no activity or transaction can take place outside the Start and End Dates and Time of the Stage as defined in the tender schedule. At the sole discretion of the Tender Authority, the time schedule of the Tender stages may be extended.




6. The detailed specifications of the required "Ductable Air Conditioner" have been given in Tender booklet.

7. University reserves the right to increase or decrease of Printers which was mentioned in This Tender/BOQ.

8. Rate to be quoted should be mentioned in figures as well as in words at appropriate place in provided in Schedule (BOQ) by the bidder, more over the rate should not be quoted anywhere else in the tender booklet as well as in the blank pages.
9. The university reserves the right to decide whether to open or not open the commercial Bid of the supplier and no objection of any supplier shall be entertained on any ground whatsoever it may be regarding this.
10. No Bidder shall be accepted without payment by online earnest money deposit and cost of tender.
11. The rate should be inclusive of GST, packing, transportation, loading and unloading charges and delivery of material shall have be to given to our **Estate Deptt., S.R.T.M.University, Nanded (Maharashtra).**
12. The rate should be offered for only the item as mentioned in the Schedule.
13. The rates quoted for the items other than make & specification specified in the tender form shall not be considered for comparison of rate.
14. The University is not to bind to accept lowest tenders and reserve the right to accept/cancel any or all tenders without assigning any reason.


 Registrar
 स्वामी रामानंद तीर्थ
 मराठवाडा विद्यापीठ, नांदेड



General Terms & Conditions



1. Tender fills up only reputed manufacturer/distributors/dealers of **"Ductable Air Conditioner"**. The firm should attach list of Institution to which it has supplied.
2. The earnest money deposit amount of **Rs.18,000/-(Eighteen thousand only)** is required to be submitted online along with tender. Otherwise submitted tender will not be considered. The vendor/firm will not be liable to get interest on this earnest money deposit amount, when refunded.
3. The bidder to whom the purchases order to be given shall be informed about the same. The bidder should deposit an appropriate amount i.e. 5% of purchase order as security deposit within 5 days from the date of Letter of intent, after which the purchase order will be issued. The security deposit will not carry any interest which shall be refunded after completion of warranty and NOC from concern Department. If the bidder fails or is incapable to keep the security deposit, then the second lowest quoted bidder will be issued the similar purchase order or the University with holds the total authority for the necessary action to be taken.
4. The successful bidder is required to execute an agreement on Rs. 100/- stamp paper. The e-tender Notice shall form part of the tender agreement.
5. The conditional tenders shall not be accepted.
6. If the supplier fails to abide by any of the terms & conditions mentioned herein EMD/Security Deposit shall be forfeited and appropriate action will be taken against supplier.
7. **F.O.R.-** The rates to be quoted - F.O.R. - should be for our **Estate Deptt., S.R.T.M. University, Nanded (Maharashtra)**. The rate quoted by the bidder should inclusive of all the taxes, Duties and other charges. The mention of Fare, Packing, Forwarding, Installation as well as Insurance and other charges should be expressed in the rate accompanied in Schedule.
8. **Validity Period:** The rate quoted by the bidder should be valid up to 180 days from the date of submitting the tender.
9. **Award of Contract:**
University reserve right to issue Award of Contract by the recommendation of Technical Committee/Electrical Deptt. for purchase of said **"Ductable Air Conditioner"**. Decision of said Technical Committee/Electrical Deptt. will be final.
10. **Delivery Period:**
The said **"Ductable Air Conditioner"** must be delivered as per agreement and terms and conditions of purchase order.
11. **Procedure for Refund of E.M.D. Amount:**
Refund of Earnest money deposit to the Unsuccessful Bidders will be get online after upload of Award of Contract (AOC) to the Successful Bidders. University will not responsible for delay in refund of E.M.D. amount after uploading of AOC. Thereafter, Bidders should contact to officials of Mahatenders regarding refund of E.MD.
12. **Refund of Security Deposit:**
Security Deposit shall be refunded after successful completion of warranty and No objection certification (NOC) from concerned Department.

13. The bidder is held responsible for replacement of "Ductable Air Conditioner" in case there occurs any kind of loss or damage of any part of the "Ductable Air Conditioner" during transportation and installation at the site.

14. Extension of Delivery Period:

Delivery period mentioned in the purchase order may be extended only in case of Special approval from University officials for extension if require and natural calamities.

15. Payments of the Bill:

As mentioned in the tender booklet the payment of the bill will be made after satisfactorily delivery & satisfactory Installation report from Technical Committee and Sample committee of this University.

16. Income Tax:

The Income Tax/TDS as per rules and surcharge thereon shall be deducted from bill amount, advance payment.


17. Cancellation of Purchase:

University reserves the right to cancel the purchase order under the following conditions in case bidder fails to supply the "Ductable Air Conditioner" within the stipulated or extended time, The University reserves the right to go for next lowest tender or other appropriate action will be taken.

- a) Due to the above mentioned reason if the tender is canceled, earnest money and security deposit shall be forfeited and also the tender may be allotted to the next lowest tender or the university reserves the right to take appropriate decision.

18. L1 will be consider of total amount of item number 1.01 to 1.10

19. In case of any dispute it will be addressed subject to Nanded district jurisdiction only.


Registrar
स्वामी रामानंद तीर्थ
मराठवाडा विद्यापीठ, नांदेड

Bidder's Declaration

E-TENDER FOR SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF DUCTABLE AIR CONDITIONERS S.R.T.M.UNIVERSITY, NANDED(MAHARASHTRA)

E-Tender No.: Estate/Ductable Air Conditioner/V.C. Office/ET-16-2025



I hereby certify that, I have gone through all the information and Terms & Conditions of the tender booklet and I accept the same. Further, I certify that, our firm is not blacklisted, debarred or prohibited by Government of India or any other State Government, Union Territory, Authority or Organization. I also declare that, no case/s, criminal or Civil or Enquires of any kind are pending against our organization. For further correspondence I provide here under the address and contact details.

Tenderer/ Name of Firm, Signature / seal

Name :

- 1 Name of Proprietor and complete address :
- 2 Telephone Numbers :
- Office :
- Residence :
- Mobile :
- Fax :
- Email :

Signature / Seal of the Bidder



E-TENDER FOR SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF DUCTABLE AIR CONDITIONERS S.R.T.M.UNIVERSITY, NANDED(MAHARASHTRA)

E-Tender No.: Estate/Ductable Air Conditioner/V.C. Office/ET-16-2025

DETAIL SPECIFICATION OF AIR CONDITIONERS

Sr.No.	Description of Ductable Air Conditioners	Qty.
1	<p>Type : <i>Ductable Inverter Air Conditioner</i> Cooling Capacity : 5 Ton / 60,000 BTU/hr Power Supply : 3-Phase, 380-415V, 50 Hz Compressor Type: DC Inverter Scroll-type Compressor Condenser Coil :100% Copper (with optional anti-corrosion coating: Blue Fin) Evaporator Coil : 100% Copper Refrigerant : R-410A Power Consumption : Approx. 4.5 – 6.5 kW Air Flow Rate 2,000 – 2,400 CFM External Static Pressure (ESP) : Medium to High (50–200 Pa) Noise Level Indoor: 45–55 dB / Outdoor: 60–70 dB Temperature Control Digital Thermostat (wired/wireless), BMS compatible Filter Type Washable high-efficiency filter Max Piping Length 30–50 meters Max Elevation Difference Up to 20 meters Safety Protections Overload, pressure protection, auto-restart, Over Voltage, Under Voltage</p>	02 Nos.
2	<i>Existing Ducting Cleaning and required on site. (Vendors must have to visit the Site)</i>	1 lot
3	<i>Duct Insulation on Existed Ducting of 19 mm thickness (As per actual condition)</i>	150 Sq mm
4	<i>Canvass Connection (As per actual condition)</i>	4 Sq mm
5	<i>Hard PVC drain piping of 25 mm did duly insulated with 6 mm Thick nitrile rubber insulation (As per actual condition)</i>	35 Mtr.
6	<i>Providing & fixing MS frame (stand Type) for outdoor ductable A. C. Unit, if required</i>	2 Nos.
7	<i>Refrigerant piping & first charge of refrigerant Supply, installation, testing & commissioning of Seamless heavy gauge copper piping of Following size duly insulated with 13 mm thk. Nitrile Rubber insulation covered with aluminium foil (As per Specified. Even necessary) supports, fittings, Joints Where ever required will be included. (As per actual condition)</i>	70 Mtr.
8	<i>Interconnecting electrical cabling between indoor & outdoor unit with GI earthing wire, (As per actual condition)</i>	100 Mtr.
9	Quote amount of buy back & dismantling of old A. C. 02 Nos.	
10	<i>Buyback and dismantling of old ductable with exited copper pipe of Unit of 5 Ton</i>	02 lot
	<p>Terms & Condition: - 1) Warranty Minimum 1 Year Comprehensive warranty on the Complete System 2) minimum 5 Years warranty on the Compressor. Annual Maintenance Contract (AMC): The AMC shall be for 3 years post-warranty. The AMC includes routine preventive maintenance (minimum 4 visits per year) and unlimited breakdown calls. AMC covers inspection, cleaning, tightening, minor repairs, refrigerant top-up (if required), and testing of electrical components. AMC does not include the cost of major components such as compressors, PCB boards, etc. unless specified. Contractor must maintain a logbook and provide service reports signed by the client after each visit.</p>	

E-TENDER FOR SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF DUCTABLE AIR CONDITIONERS

S.R.T.M.UNIVERSITY, NANDED(MAHARASHTRA)

E-Tender No.: Estate/Ductable Air Conditioner/V.C. Office/ET-16-2025

Tender Schedule

Sr. No	Key Days of the Tender	Start Date & Time	Expiry Date & Time
1	Tender Release	10 -09-2025 15:00	12 .09.2025 15.00
2	Tender document downloading	12 -09-2025 15:01	19 .09.2025 15:00
3	Online submission	12 -09-2025 15:01	19 .09.2025 15:00
4	Technical Bid opening& short listing	22 -09-2025 15:00	---
5	Financial Bid opening	23 -09-2025 15:00 (If Possible)	---

Contact below Nos., If any Query

- 1) Toll free Nos.: : 1800 3070 2232
- 2) Technical Enquiry : Shri.A.M.Dhakde
Dy.Engineer(Electrical)
S.R.T.M.University,Nanded
Mob.No.: 7020896882
- 3) Tender Enquiry : 02462 215252 (Finance & Accounts Officer)
02462 215575 (Superintendent, Estate Deptt.)

कुलसचिव
स्वामी रामानंद तीर्थ
मराठवाडा विद्यापीठ



**E-TENDER FOR SUPPLY, INSTALLATION, TESTING &
COMMISSIONING OF DUCTABLE AIR CONDITIONERS
S.R.T.M.UNIVERSITY, NANDED(MAHARASHTRA)**

E-Tender No.: Estate/Air Conditioner/V.C. Office/ET-16-2025

Appendix – II

Item Code	Particulars	Company/Brand	Bidder should Mention Company/Brand (With detail specification) to be Supply
1	Type : Ductable Inverter Air Conditioner Cooling Capacity : 5 Ton / 60,000 BTU/hr Power Supply : 3-Phase, 380–415V, 50 Hz Compressor Type: DC Inverter Scroll-type Compressor Condenser Coil :100% Copper (with optional anti-corrosion coating: Blue Fin) Evaporator Coil : 100% Copper Refrigerant : R-410A Power Consumption : Approx. 4.5 – 6.5 kW Air Flow Rate 2,000 – 2,400 CFM External Static Pressure (ESP) : Medium to High (50–200 Pa) Noise Level Indoor: 45–55 dB / Outdoor: 60–70 dB Temperature Control Digital Thermostat (wired/wireless), BMS compatible Filter Type Washable high-efficiency filter Max Piping Length 30–50 meters Max Elevation Difference Up to 20 meters Safety Protections Overload, pressure protection, auto-restart, Over Voltage, Under Voltage	Daikin/Blue Star/Carrier/O-general/Hitachi/Voltas	
2	Existing Ducting Cleaning and required on site. (Vendors must have to visit the Site)	---	
3	Duct Insulation on Existed Ducting of 19 mm thickness (As per actual condition)	---	
4	Canvass Connection (As per actual condition)	---	
5	Hard PVC drain piping of 25 mm did duly insulated with 6 mm Thick nitrile rubber insulation (As per actual condition)	---	
6	Providing & fixing MS frame (stand Type) for outdoor ductable A. C. Unit, if required	---	
7	Refrigerant piping & first charge of refrigerant Supply, installation, testing & commissioning of Seamless heavy gauge copper piping of Following size duly insulated with 13 mm thk. Nitrile Rubber insulation covered with aluminium foil (As per Specified. Even necessary) supports, fittings, Joints Where ever required will be included. (As per actual condition)	---	
8	Interconnecting electrical cabling between indoor & outdoor unit with GI earthing wire, (As per actual condition)	---	
9	Quote amount of buy back & dismantling of old A. C. 02 Nos.	---	
10	Buyback and dismantling of old ductable with exited copper pipe of Unit of 5 Ton	---	



Sl. No.	Item Description	Estimated Quantity	Units per Nos.	BASIC RATE In Figures To be entered by the Bidder in Rs. P	GST (If applicable in Percentage)	GST Amount in Rs. P	TOTAL AMOUNT excluding taxes in Rs. P	TOTAL AMOUNT including taxes in Rs. P	TOTAL AMOUNT In Words
1	2	4	5	7	8	9	11	12	13
1	Supply Ductable Inverter Air Conditioner for S.R.T.M. University, Nanded.								
1.01	Type : Ductable Inverter Air Conditioner Cooling Capacity : 5 Ton / 60,000 BTU/hr Power Supply : 3-Phase, 380-415V, 50 Hz Compressor Type: DC Inverter Scroll-type Compressor Condenser Coil :100% Copper (with optional anti-corrosion coating: Blue Fin) Evaporator Coil : 100% Copper Refrigerant : R-410A Power Consumption : Approx. 4.5 – 6.5 kW Air Flow Rate 2,000 – 2,400 CFM External Static Pressure (ESP) : Medium to High (50-200 Pa) Noise Level Indoor: 45-55 dB / Outdoor: 60-70 dB Temperature Control Digital Thermostat (wired/wireless), BMS compatible Filter Type Washable high-efficiency filter Max Piping Length 30-50 meters Elevation Difference Up to 20 meters Safety Protections Overload, pressure protection, auto-restart, Over Voltage, Under Voltage (Warranty and AMC as per mention in the Tender Document)	2.00 Nos				0.00	0.000	0.000	INR Zero Only
1.02	Existing Ducting Cleaning and required on site. (Vendors must have to visit the Site)	1.00 Lot				0.00	0.000	0.000	INR Zero Only
1.03	Duct Insulation on Existed Ducting of 19 mm thickness (As per actual condition)	150.00 Sq mm				0.00	0.000	0.000	INR Zero Only
1.04	Canvass Connection (As per actual condition)	4.00 Sq mm				0.00	0.000	0.000	INR Zero Only
1.05	Hard PVC drain piping of 25 mm did duly insulated with 6 mm Thick nitrile rubber insulation (As per actual condition)	35.00 Mtr.				0.00	0.000	0.000	INR Zero Only
1.06	Providing & fixing MS frame (stand Type) for outdoor ductable A. C. Unit, if required	2.00 Nos				0.00	0.000	0.000	INR Zero Only



Sl. No.	Item Description	Estimated Quantity	Units per Nos.	BASIC RATE in Figures To be entered by the Bidder in Rs. P	GST (if applicable in Percentage)	GST Amount in Rs. P	TOTAL AMOUNT excluding taxes in Rs. P	TOTAL AMOUNT including taxes Rs. P	TOTAL AMOUNT in Words
1	2	4	5	7	8	9	11	12	13
1	Supply Ductable Inverter Air Conditioner for S.R.T.M.University,Nanded.								
1.07	Refrigerant piping & first charge of refrigerant Supply, installation, testing & commissioning of Seamless heavy gauge copper piping of Following size duly insulated with 13 mm thk. Nitrile Rubber insulation covered with aluminium foil (As per Specified. Even necessary) supports, fittings, Joints Where ever required will be included. (As per actual condition)	70.00	Mtr.			0.00	0.000	0.000	INR Zero Only
1.08	Interconnecting electrical cabling between indoor & outdoor unit with GI earthing wire, (As per actual condition)	100.00	Mtr.			0.00	0.000	0.000	INR Zero Only
1.09	Quote amount of buy back & dismantling of old A. C. 02 Nos.	2.00	Nos			0.00	0.000	0.000	INR Zero Only
1.10	Buyback and dismantling of old ductable with exited copper pipe of Unit of 5 Ton	2.00	Lot			0.00	0.000	0.000	INR Zero Only
Total in Figures							0.000	0.000	INR Zero Only
Quoted Rate in Words							INR Zero Only		

कुलसचिव
श्रीराम रामानंद तीर्थ
मैराठवाडा विद्यापीठ, नांदेड

4.11